

CONTRACTOR’S INQUIRY RESPONSES

**STORM DRAINAGE REPAIR OF
COLLIER CANYON ROAD AT MILE MARKER 3.66
MURRY TOWNSHIP, ALAMEDA COUNTY, CALIFORNIA**

The responses to contractors' inquiries, unless incorporated into a formal addendum to the contract, are not a part of the contract and are provided for the contractor's convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The responses may be considered along with all other information furnished to prospective bidders for the purpose of bidding on the project. The availability or use of information provided in the responses to contractors' inquiries is not to be construed in any way as a waiver of the provisions of section 2-1.07 of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications or Special Provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary a response previously given and any such subsequent response or addenda should be taken into consideration when submitting a bid for the project. Inquiries must be submitted by the deadline specified in the project Special Provisions.

This document will be continuously updated. It is the contractor’s responsibility to check for updates.

UPDATED (3-27-2026): *(Legend: T = telephone; PBM = pre-bid meeting; E = email)*

Inquiry No.	Inquiry	Response
1E	Bid Item 42 on the Bid List doesn’t have a Unit listed	The Unit for Bid Item 42 should be LF. Please see Addendum #1.
2E	Will the existing overhead powerlines be relocated or De-Energized for the temporary shoring?	The existing overhead powerlines will not be relocated or De-Energized for the temporary shoring. Note 1 on sheet 15 in the contract plans states, “Actual limits of the shoring and design are the responsibility of the contractor”. This is further discussed in Section 48-7 of the special provisions. It is the contractor’s responsibility to follow all OSHA guidelines, including maintaining safe offsets from the utility lines.