

CONTRACTOR'S INQUIRY RESPONSES
SPECIFICATION NO. 2504
THE IMPROVEMENTS OF NORBRIDGE AVENUE
FROM 230 SOUTH OF STANTON AVENUE TO TYEE COURT
CSATRO VALLEY, ALAMEDA COUNTY, CALIFORNIA

The responses to contractors' inquiries, unless incorporated into a formal addendum to the contract, are not a part of the contract and are provided for the contractor's convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The responses may be considered along with all other information furnished to prospective bidders for the purpose of bidding on the project. The availability or use of information provided in the responses to contractors' inquiries is not to be construed in any way as a waiver of the provisions of section 2-1.07 of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications or Special Provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary a response previously given and any such subsequent response or addenda should be taken into consideration when submitting a bid for the project. Inquiries must be submitted by the deadline specified in the project Special Provisions.

This document will be continuously updated. It is the contractor's responsibility to check for updates.

Inquiry No.	Inquiry	Response
1	Please confirm the bid unit for #21 as it appears to be SF, not SY.	Bid unit for Bid Item #21 is Square Foot (SF). See Addendum 1
2	Please confirm the quantity of #28 as Sheet 16 shows over 2,000 SY.	See Addendum 1 for updated quantity for Bid Item #28.
3	Please confirm if the C&G is monolithic or not.	Curb and Gutter is monolithic.
4	Please confirm the quantity of #23, #24 and #25	See Addendum 1 for updated quantities for only Bid Items #24 and #25. Bid Item #23 is confirmed.
5	Can the retaining curb be placed monolithically with the sidewalk?	Yes
6	What stations contain the hazardous waste for Bid Item #20?	Based on the composite soil analytical result, all soils along the Norbridge project limits exceed the California hazardous waste threshold for lead and should be managed and disposed of as California hazardous waste. See Addendum 1 (addition of Exhibit 1 and Figure 1 to Information Handout J) for the summary data table and sample location drawing for reference.